

# Obtrusive Light - Compliance Report

AS 4282-1997, Pre-Curfew, Residential - Light Surrounds

Filename: 371 Five Dock

1/11/2016 4:35:34 AM

## Illuminance

Maximum Allowable Value: 10 Lux

Calculations Tested (3):

Calculation Label	Test Results	Max. Illum.	
ObtrusiveLight_1_Ill_Seg1	PASS	8.7	
ObtrusiveLight_2_Ill_Seg1	PASS	0.2	
ObtrusiveLight_3_Ill_Seg1	PASS	0.1	

## Luminous Intensity (Cd) Per Luminaire

Maximum Allowable Value: 7500 Cd

Control Angle: 83 Degrees

Luminaire Locations Tested (12)

Test Results: **PASS**

All Luminaire Locations (12):

Lum.No.	Label	Cd	Tilt	Roll	Spin
1	A3 Maxi 2000W T10 N	1183	-2	0	0
7	A3 Maxi 2000W T10 N	1183	-2	0	0
9	A3 Maxi 2000W T10 N	1183	-2	0	0
11	A3 Maxi 2000W T10 N	1183	-2	0	0
2	A3 Maxi 2000W T10 N	3375	0	0	0
3	A3 Maxi 2000W T10 N	3375	0	0	0
4	A3 Maxi 2000W T10 N	3375	0	0	0
5	A3 Maxi 2000W T10 N	3375	0	0	0
6	A3 Maxi 2000W T10 N	3375	0	0	0
8	A3 Maxi 2000W T10 N	3375	0	0	0
12	A3 Maxi 2000W T10 N	3375	0	0	0
13	A3 Maxi 2000W T10 N	3375	0	0	0